

TOWN OF GANDER



OC25-05

GANDER WTP COMPRESSOR REPLACEMENT

ADDENDUM No. 1
January 7, 2026

CLOSING DATE Wednesday January 14th, 2026 @ 2:00:00 PM (UNCHANGED)
OPENING DATE Wednesday January 14th, 2026 @ 2:30:00 PM (UNCHANGED)

**Opening will take place at the Town Hall, in the Lancaster Room,
100 Elizabeth Drive, Gander, NL**

The following changes or modifications shall be made to the Tender Documents:

TO THE DRAWINGS

DRAWING 253032.00-E-02

Delete Drawing 253032.00-E-02 (Rev. 0 – ISSUED FOR TENDER) **and replace with** Drawing 253032.00-E-02 (Rev. 1 – ISSUED FOR ADDENDUM 1) dated January 7, 2026, attached.

DRAWING 253032.00-P-01

To Detail 1 “Compressed Air System – Schematic and Scope of Work”, add note: “NOTE THAT ALL EXISTING EQUIPMENT SHOWN TO THE RIGHT OF TP-01, TP-02 AND TP-03 IS EXISTING TO REMAIN.”

DRAWING 253032.00-P-03

Under 8.0 *CONTRACTOR SUPPLIED EQUIPMENT*:

Part 1.1.1, **delete** “HORIZONTAL (WET) TANK MOUNTED” **and replace with** “BASE MOUNTED”.

Part 1.1.2.2 **delete** “3600 RPM”.

Part 1.1.3.1 **delete and replace with** “MANUAL LOCAL CONTROL VIA PHYSICAL OR ELECTRONIC H-O-A SWITCH”.

Part 1.1.6 **delete** “RECIPROCATING” **and replace with** “SCREW”.

END OF ADDENDUM 1