

TOWN OF GANDER



OC25-05

GANDER WTP COMPRESSOR REPLACEMENT

ADDENDUM No. 2
January 13, 2026

CLOSING DATE Wednesday, January 21st, 2026 @ 2:00 p.m. (CHANGED)
OPENING DATE Wednesday, January 21st, 2026 @ 2:30 p.m (CHANGED)

**Opening will take place at the Town Hall, in the Lancaster Room,
100 Elizabeth Drive, Gander, NL**

OC25-05 GANDER WTP COMPRESSOR REPLACEMENT – Addendum No. 2 – January 13, 2026

The following changes or modifications shall be made to the Tender Documents:

Q: Does the MCC need to be modified and recertified as indicated on E04 after the Addendum 1 changes?

A: No, the MCC does not need to be modified and recertified. Existing feeds to be repurposed as indicated on the revised Addendum 1 E02 drawing. Any changes to the scope of work which require the contractor to engage the MCC manufacturer to modify and recertify the MCC will be addressed as a change order.

TO THE DRAWINGS

DRAWING 253032.00-E-04

Delete Section 'Motor Control Centres' and corresponding sub sections (1 – Products and 2 – Installation) from the drawing.

END OF ADDENDUM 2
